



**CITY OF DULUTH**  
PURCHASING DIVISION  
Room 100 City Hall  
411 West First Street  
Duluth, Minnesota 55802-1199  
218/730-5340 218/730-5922 FAX  
[purchasing@duluthmn.gov](mailto:purchasing@duluthmn.gov)

**Addendum 1**  
**File # 17-0444**

**Project: Pre-Insulated Hot Water Pipe Valves and Fittings – 20” ID (Series 2)**

This addendum serves to notify all bidders of the following changes to the solicitation documents:

The following question is answered below:

Q: The pipe description makes reference to ‘series 2.’ Please indicate specific outer jacket diameter to quote for all three pipe/fitting sizes.

A: Here are the outside diameters of all three pipes:

Outer Jacket Dimensions:

20” – 800mm/31.4”

2” – 140mm/5.5”

1-1/4” – 125mm/5”

Please acknowledge receipt of this Addendum by initialing and dating Addendum #1 below the bid form on the invitation for bids.

Posted: June 28, 2017